



Water Sustainability & Conservation in an Exhaust Cooling Discharge System Case Study

17 Jun 10

**Kimberly Ehret
Environmental Engineer
AFRL/RZOOE
Air Force Research Laboratory**

Report Documentation Page				Form Approved OMB No. 0704-0188	
Public reporting burden for the collection of information is estimated to average 1 hour per response, including the time for reviewing instructions, searching existing data sources, gathering and maintaining the data needed, and completing and reviewing the collection of information. Send comments regarding this burden estimate or any other aspect of this collection of information, including suggestions for reducing this burden, to Washington Headquarters Services, Directorate for Information Operations and Reports, 1215 Jefferson Davis Highway, Suite 1204, Arlington VA 22202-4302. Respondents should be aware that notwithstanding any other provision of law, no person shall be subject to a penalty for failing to comply with a collection of information if it does not display a currently valid OMB control number.					
1. REPORT DATE 17 JUN 2010		2. REPORT TYPE		3. DATES COVERED 00-00-2010 to 00-00-2010	
4. TITLE AND SUBTITLE Water Sustainability & Conservation in an Exhaust Cooling Discharge System Case Study				5a. CONTRACT NUMBER	
				5b. GRANT NUMBER	
				5c. PROGRAM ELEMENT NUMBER	
6. AUTHOR(S)				5d. PROJECT NUMBER	
				5e. TASK NUMBER	
				5f. WORK UNIT NUMBER	
7. PERFORMING ORGANIZATION NAME(S) AND ADDRESS(ES) Air Force Research Laboratory, AFRL/RZOE, Wright Patterson AFB, OH, 45433				8. PERFORMING ORGANIZATION REPORT NUMBER	
9. SPONSORING/MONITORING AGENCY NAME(S) AND ADDRESS(ES)				10. SPONSOR/MONITOR'S ACRONYM(S)	
				11. SPONSOR/MONITOR'S REPORT NUMBER(S)	
12. DISTRIBUTION/AVAILABILITY STATEMENT Approved for public release; distribution unlimited					
13. SUPPLEMENTARY NOTES Presented at the NDIA Environment, Energy Security & Sustainability (E2S2) Symposium & Exhibition held 14-17 June 2010 in Denver, CO.					
14. ABSTRACT					
15. SUBJECT TERMS					
16. SECURITY CLASSIFICATION OF:			17. LIMITATION OF ABSTRACT Same as Report (SAR)	18. NUMBER OF PAGES 39	19a. NAME OF RESPONSIBLE PERSON
a. REPORT unclassified	b. ABSTRACT unclassified	c. THIS PAGE unclassified			



Component Research Air Facility (CRAF)



- **Simulates high altitude conditions for aircraft and aviation fuels research**
- **Exhaust >3000 F at flows >36,000 cfm**
- **Cooled by water to 100 F**
- **Up to 1000 gpm water flow**





Challenge

- **Design an Exhaust Cooling Discharge System (ECDS)**
 - **Treat free product**
 - **Treat emulsified fuel in water**
 - **Treat 300,000 gallons of water/research effort**
 - **Efficiently cool while limiting wastes**
 - **Determine viability of using fuel contaminated water to cool**
 - **Determine ability to recycle the water**
 - **Work within existing infrastructure**



Technologies Evaluated



- **Oil/Water Separator (OWS)**
- **Air-Sparged Hydrocyclone**
- **Direct Sanitary Discharge**
- **Diffused Air Flotation (DAF)**
- **OWS & Clay Towers – discharge to storm or sanitary**
- **OWS & Clay Towers – closed loop system**



Ranking Parameters




- **Initial cost**
- **Recurring annual cost**
- **Installation cost**
- **Risk**



Oil/Water Separator



- **Mechanical separation of oil and water**
- **Pros**
 - **Separates free product**
- **Cons**
 - **Cannot separate emulsified fuels**



* Optional equipment available from Highland Tank

** Installer supplied equipment



Air-Sparged Hydrocyclone



- **Removes hydrophobic particles from aqueous solutions**
- **Vehicle wash racks & engine test cells**
- **Pros**
 - High removal of oil & grease
- **Cons**
 - Low flows 20 gpm – 250 gpm



Direct Sanitary Discharge



- **OWS – Separates free product – discharge to sanitary**
- **Pros**
 - No EPA compliance monitoring
 - No waste disposal
 - No chemical handling
- **Cons**
 - Existing line too small
 - Disposal costs for sewage (present & future)
 - Lack of water conservation



Diffused Air Flotation

- **Chemicals used to flocculate emulsified fuels**
- **Air bubbles raise fuel to surface**
- **Pros**
 - **Meets compliance levels for storm water discharge**
- **Cons**
 - **Large footprint needed**
 - **Recurring waste production –sludge disposal**
 - **EPA compliance monitoring (storm water)**
 - **Chemical purchases and handling**



OWS & Clay Towers – Discharge to Storm or Sanitary



- **OWS – removes free product**
- **Clay towers – remove emulsified fuel**
- **Pros**
 - Can meet storm water compliance
 - No chemical handling
- **Cons**
 - Replacement of clay & waste disposal
 - Compliance monitoring
 - Freezing problems



OWS & Clay Towers – Closed Loop



- **OWS – removes free product**
- **Clay towers – remove emulsified fuel**
- **Pros**
 - Recycles water
 - Can meet storm water compliance or can discharge to existing sanitary
 - No chemical handling
- **Cons**
 - Replacement of clay & waste disposal
 - Freezing problems
 - Fuel in recycled water



Selection Parameters (1 Lowest , 4 Highest)




	Initial Costs	Annual/ Recurring	Installation months	Risk
Sanitary Line	3	1	3	1
Closed Loop	2	3	2	2
OWS with Clay	1	3	1	3
DAF	4	2	4	4



Preferred Option



- **Closed Loop**
 - Can it actually be accomplished?
- **Additional Details**
 - **Estimate fuel concentration in recycled water**
 - Can it safely be recycled to cool exhaust?
 - Can water be recycled without clay?
 - **Can existing sanitary line be used?**
 - **How much water needs to be stored for release to sanitary?**
 - **Infrastructure limitations**



REVISION	DESCRIPTION	DATE	APPROVED
1	ISSUED FOR CONSTRUCTION	11/11/09	ALR

REVISIONS

NO.	DESCRIPTION	DATE	BY
1	ISSUED FOR CONSTRUCTION	11/11/09	ALR



Tahoe
ENGINEERING & CONSTRUCTION

**AIR FORCE RESEARCH
LABORATORY**
WALLINGFORD, VT
F055-PF06MF



Fuel Concentration



- **4000 ppm average (200 gal fuel, 50,000 gal water)**
- **Not to exceed 15,000 ppm**
- **Measured concentration in trial run**
 - 600 ppm time 0
 - 250 ppm time 2hrs
- **Water with emulsified fuel can be recycled safely without clay polishing**



Sanitary Line



- **OWS ensures free product capture**
- **Sanitary line survey conducted**
 - Existing line - <200 gpm discharge acceptable
- **Flashpoint test**
 - > 140 F for emulsified fuel
- **Discharge temperature**
 - < 70 F
- **Existing line can be used for discharge**



Water Storage



- **60,000 - 100,000 gallons**
- **2 or 3 tanks 35,000 gallons each**



Infrastructure Limitations



- **Location of 1500 gpm OWS**
- **Location of 35,000 gallon towers**































Conclusion

- **Closed Loop System can be accomplished**
 - Unique combination of OWS, two-35,000 gallon storage tanks, recirculation of water to cool the exhaust and low flow controlled discharge to sanitary sewer



* Optional equipment available from Highland Tank
 ** Installer supplied equipment









Conclusion (Cont)



- **Recirculation saves approximately 20M gallons of water/year**